



City of Auburndale

Residential Above Ground Pool Checklist

All permit application packages must be complete prior to acceptance. You must check each box to the left or indicate N/A on this submittal. For questions, please email permit@auburndalefl.com

- Above ground pools shall be provided with a minimum 48" high barrier placed a minimum of 20' from the above ground pool which complies with the requirements of Section FBC-R 4501.17.3 of the Florida Building Code
- The wall of the above ground pool may be utilized as the pool safety barrier provided the walls are at least 48' above finished grade and the only access to the pool is by means of a removable ladder or steps.
- If a fence or enclosure is installed, the walls shall be a minimum 48" above the finished grade. The gates or doors must open outwards, be self-closing and self-latching. The latch released device must be 54" above the finished grade or located on the inside of the gate and shielded or otherwise protected from opening through the gate
- The electrical installation shall comply with Article 680 of the National Electric Code.
- Pools shall not be located under or within 10' horizontal distance of overhead power lines unless a minimum 22.5' clearance is provided from the electrical lines to the top of the pool.
- Pools shall not be located over or within 5' horizontally of underground electrical wiring of septic tanks.
- Pool pump motor shall be fed with a minimum #12 equipment grounding conductor and installed in rigid metal, intermediate metal, or rigid nonmetallic conduit.
- Pool pump motors shall be GFCI protected as required by the manufacturer
- Pool pumps directly wired must have a disconnect located 5' minimum from pool
- Pool pump cord connected must comply with the following
 - Single receptacle
 - Locking configuration
 - Grounding type
 - GFCI protected
 - 6' minimum from pool edge
- All metal parts within 5' of the pool and pool shell of the above ground pool shall be bonded to the pool motor. The pool motor shall be listed and labeled for swimming pool or spa use.
- A GFCI protected convenience outlet is required between 6' and 20' of the above ground pool. No electrical receptacles are allowed within 6" of the pool.
- Properly grounded system is required as per the National Electric Code.